



2022-2023 Statement of Assurance (SOA) for Testing and Reporting of Lead in School Drinking Water

Representative Title: Business Administrator
Representative Name: Sophia Clarke
Representative E-Mail: sclarke@essexvalleyschool.org
Submission Date: 6/26/2023

Entity Type: APSSD
County: ESSEX
Entity: ESSEX VALLEY SCHOOL (8243)
School Address: 1 Henderson Drive, West Caldwell NJ 07006

Exemption: NO

Testing was completed between the designated period of July 1, 2021 to June 30, 2022: TRUE

Website address of test results: <https://www.essexvalleyschool.org/current/lead-water-testing-2023>

Did any lead test results exceed the action level of 15 µg/L?: NO

Alternate drinking water is provided for outlets that are closed or unavailable: TRUE

The district or school entity assures that testing and reporting for lead drinking water was completed and maintains compliance in accordance with N.J.A.C. 6A:26-12.4: TRUE



Garden State Laboratories, Inc.

Report Date: 06/23/2023

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Essex Valley School
1 Henderson Dr.

West Caldwell, NJ 07006

Laboratory Director:

Attention: Kenneth Kittle

Client Number: ESS11

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/Field
Blank

Lab Sample ID: 230612050-01

Site: Collection Date/Time: 06/09/2023 06:05

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:28	

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/100
Unisex Bath

Lab Sample ID: 230612050-02

Site: Collection Date/Time: 06/09/2023 06:05

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:31	

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006//102
Nurse

Lab Sample ID: 230612050-03

Site: Collection Date/Time: 06/09/2023 06:07

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:40	



Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/102A
Nurse Bath

Lab Sample ID: 230612050-04

Site: Collection Date/Time: 06/09/2023 06:09

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:42	

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/105
Middle School Cafe

Lab Sample ID: 230612050-05

Site: Collection Date/Time: 06/09/2023 06:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00111 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:45	

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/201
Cosmetology Sink

Lab Sample ID: 230612050-06

Site: Collection Date/Time: 06/09/2023 06:12

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:48	

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/Staff
Men

Lab Sample ID: 230612050-07

Site: Collection Date/Time: 06/09/2023 06:14

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:51	



Sample ID: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006/Staff Women
 Lab Sample ID: 230612050-08
 Site: Collection Date/Time: 06/09/2023 06:16
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.0134 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:54	

Sample ID: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006/302 Food Prep
 Lab Sample ID: 230612050-09
 Site: Collection Date/Time: 06/09/2023 06:18
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:56	

Sample ID: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006/302A Food Island
 Lab Sample ID: 230612050-10
 Site: Collection Date/Time: 06/09/2023 06:20
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 11:59	

Sample ID: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006/302C Ice
 Lab Sample ID: 230612050-11
 Site: Collection Date/Time: 06/09/2023 06:22
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 12:02	



Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/Male
Student Bank

Lab Sample ID: 230612050-12

Site: Collection Date/Time: 06/09/2023 06:25

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/20/23 12:05	

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/Female
Student Bank

Lab Sample ID: 230612050-13

Site: Collection Date/Time: 06/09/2023 06:27

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00149 mg/l	0.015	0.00100	0.00055	20044	06/21/23 12:58	

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/400
Water Fountain

Lab Sample ID: 230612050-14

Site: Collection Date/Time: 06/09/2023 06:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/22/23 10:50	

Sample ID: Essex Valley School, 1
Henderson Drive, West
Caldwell, NJ 07006/Staff
Lounge Sink

Lab Sample ID: 230612050-15

Site: Collection Date/Time: 06/09/2023 06:31

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00377 mg/l	0.015	0.00100	0.00055	20044	06/22/23 10:53	



Sample ID: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006/Gym Fountain
 Lab Sample ID: 230612050-16

Site: Collection Date/Time: 06/09/2023 06:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00255 mg/l	0.015	0.00100	0.00055	20044	06/22/23 10:56	

Sample ID: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006/Gym Bottle Filler
 Lab Sample ID: 230612050-17

Site: Collection Date/Time: 06/09/2023 06:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/22/23 10:59	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit, MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified. The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.



Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/12/23 15:34 1.8°C

Page 1 of 4

GSL CLIENT # ESS11

MICRO #

CHEM. # 230612050-01-05

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Essex Valley School Contact/Authorized by: Kenneth Kittle

Mailing Address: 1 Henderson Drive Phone: 973-244-7890

City/State/Zip: West Caldwell, NJ 07006 Email: kkittle@essex.valleyschool.org

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab #
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Field Blank	6/9/23	6:05	X		Lead (First Draw)	1	P	250ml	A	50-01
X		100 UNISEX BATH	6/9/23	6:05	X		Lead (First Draw)	1	P	250ml	A	50-02
X		102 NURSE	6/9/23	6:07	X		Lead (First Draw)	1	P	250ml	A	50-03
X		102A NURSE BATH	6/9/23	6:09	X		Lead (First Draw)	1	P	250ml	A	50-04
X		105 MIDDLE SCHOOL CAFE	6/9/23	6:10	X		Lead (First Draw)	1	P	250ml	A	50-05

⇒ Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 ⇒ Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Ithiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

SUBCONTRACTED WORK

TURNAROUND TIME: Standard Rush (if RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORM: Standard Report Other/Specify:

DATE/TIME:

Standard Report + E2 PWS ID#:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$

Payment Method: Credit Card Type: Check # Other: See Quote

Note: LEAD SAMPLING FOR SCHOOL FACILITY ON PUBLIC WATER SYSTEM

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Kenneth J Kittle	Signature: <i>Kenneth J Kittle</i>	Date/Time: 6/9/23 6:25 AM
Client/Client's Representative (PRINT): Kenneth J Kittle	Signature: <i>Kenneth J Kittle</i>	Date/Time: 6-9-23 11:17 AM
1. Received/Relinquished by (PRINT): <i>Don B...</i>	Signature: <i>Don B...</i>	Date/Time: 6/12/23
2. Received/Relinquished by (PRINT): <i>W. H. Stone</i>	Signature: <i>W. H. Stone</i>	Date/Time: 6/12/23

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

15:34

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Essex Valley School Contact/Authorized by: Kenneth Kittle
 Mailing Address: 1 Henderson Drive Phone: 973-244-7890
 City/State/Zip: West Caldwell, NJ 07006 Email: kkittle@essex.valleyschool.org

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATI: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/12/23 15:34 18°C

Page 2 of 4

GSL CLIENT # ESS11

MICRO #

CHEM. # 220612050-06-10

SAMPLE REC'D BY:

- GSL FIELD SAMPLER/PICK-UP
 PICK-UP AT DROP OFF LOCATION
 DELIVERED BY CLIENT

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM	<input type="checkbox"/> List attached Total Pages	No.	Type*	Size	Pres.*	
X	201 COSMETOLOGY STAFF	6/9/23	6:12	X		<input type="checkbox"/> Lead (First Draw)	1	P	250ml	A	50-06
X	STAFF MEN	6/9/23	6:14	X		<input type="checkbox"/> Lead (First Draw)	1	P	250ml	A	50-07
X	STAFF WOMEN	6/9/23	6:16	X		<input type="checkbox"/> Lead (First Draw)	1	P	250ml	A	50-08
X	302 FOOD PREP	6/9/23	6:18	X		<input type="checkbox"/> Lead (First Draw)	1	P	250ml	A	50-09
X	302A FOOD ISLAND	6/9/23	6:20	X		<input type="checkbox"/> Lead (First Draw)	1	P	250ml	A	50-10

⇒ Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Thio V = Vial Other/Specify:
 ⇒ Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify:

TURNAROUND TIME: Standard Rush (if RUSH REQUESTED) Rush Due by:
 REPORT FORM: Standard Report Other/Specify:
 Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

SUBCONTRACTED WORK

SEND TO:
 DATE/TIME:
 METHOD OF SHIPMENT:

Note: LEAD SAMPLING FOR SCHOOL FACILITY ON PUBLIC WATER SYSTEM

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Kenneth J Kittle Signature: Kenneth J Kittle Date/Time: 6/9/23 6:35 AM
 Client/Client's Representative (PRINT): Kenneth J Kittle Signature: Kenneth J Kittle Date/Time: 6-12-23 11:17A
 1. Received/Relinquished by (PRINT): Olga K... Signature: Olga K... Date/Time: 6/12/23
 2. Received/Relinquished by (PRINT): T. Alston Signature: T. Alston Date/Time: 6/12/23

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

15:34

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/12/23 15:34 1.8°C

Page 3 of 4

GSL CLIENT # ESS11

MICRO #

CHEM. # 237612050-11-15

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Essex Valley School Contact/Authorized by: Kenneth Kittle
 Mailing Address: 1 Henderson Drive Phone: 973-244-7890
 City/State/Zip: West Caldwell, NJ 07006 Email: kkittle@essex.valleyschool.org

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATI: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006

Grab/Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X	302 c ICE	6/9/23	6:22	X		1	P	250ml	A	50-11	
X	MALE STUDENT BANK	6/9/23	6:25	X		1	P	250ml	A	50-12	
X	FEMALE STUDENT BANK	6/9/23	6:27	X		1	P	250ml	A	50-13	
X	400 WATER FOUNTAIN	6/9/23	6:29	X		1	P	250ml	A	50-14	
X	STAFF COACHES SENE	6/9/23	6:31	X		1	P	250ml	A	50-15	

Container Type: P=Plastic G=Glass A=Amber Glass T=Sterile Thio V=Vial Other/Specify:
 Preservation Code: A=Non Preserved B=Sulfuric Acid C=Sodium Hydroxide D=Nitric Acid
 E=Hydrochloric Acid F=Zinc Acetate G=Sodium Ithiosulfate H=Ascorbic Acid I=Cooled Other/Specify:

SUBCONTRACTED WORK

TURNAROUND TIME: Standard Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORM: Standard Report Other/Specify:

Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$

Payment Method: Credit Card Type: Check # Other: See Quote

Note: LEAD SAMPLING FOR SCHOOL FACILITY ON PUBLIC WATER SYSTEM

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): Kenneth J Kittle Signature: Kenneth J Kittle Date/Time: 6/9/23 6:35 AM
 Client/Client's Representative (PRINT): Kenneth J Kittle Signature: Kenneth J Kittle Date/Time: 6/12/23 11:18 AM
 1. Received/Relinquished by (PRINT): [Signature] Signature: [Signature] Date/Time: 6/12/23
 2. Received/Relinquished by (PRINT): [Signature] Signature: [Signature] Date/Time: 6/12/23

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

15.34

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:
 6/12/23 15:34 7.8°C

Page 4 of 4

GSL CLIENT # ESS11

MICRO #

CHEM. # 235102050-16-17

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Essex Valley School Contact/Authorized by: Kenneth Kittle
 Mailing Address: 1 Henderson Drive Phone: 973-244-7890
 City/State/Zip: West Caldwell, NJ 07006 Email: kkittle@essex.valleyschool.org

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATI: Essex Valley School, 1 Henderson Drive, West Caldwell, NJ 07006

Grab Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM	<input type="checkbox"/> List attached Total Pages	No.	Type*	Size	Pres.*	
X	GPM FOUNTAIN	6/9/23	6:33	X		Lead (First Draw)	1	P	250ml	A	50-10
X	GPM BOTTLE FILLER	6/9/23	6:35	X		Lead (First Draw)	1	P	250ml	A	50-17

Container Type: P=Plastic G=Glass A=Amber Glass T=Sterile Thio V=Vial Other/Specify:
 Preservation Code: A=Non Preserved B=Sulfuric Acid C=Sodium Hydroxide D=Nitric Acid
 E=Hydrochloric Acid F=Zinc Acetate G=Sodium I nosulfate H=Ascorbic Acid I=Cooled Other/Specify:

SUBCONTRACTED WORK

TURNAROUND TIME: Standard Rush (if RUSH REQUESTED) Rush Due by:

REPORT FORM: Standard Report Other/Specify:

Standard Report + E2 PWS ID#:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$

Payment Method: Credit Card Type: Check # Other: See Quote

Note: LEAD SAMPLING FOR SCHOOL FACILITY ON PUBLIC WATER SYSTEM

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): Kenneth J Kittle Signature: Kenneth J Kittle Date/Time: 6/9/23 6:35 AM
 Client/Client's Representative (PRINT): Kenneth J Kittle Signature: Kenneth J Kittle Date/Time: 6-12-23 11:12 AM
 1. Received/Relinquished by (PRINT): Olaya Bayeh Signature: Olaya Bayeh Date/Time: 6/12/23
 2. Received/Relinquished by (PRINT): T. Alston Signature: T. Alston Date/Time: 6/12/23 15:34

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED